

P/N 116095
REV. 8/95
C-146
US \$75.00

Instruction Manual for the LAD Series

LAD Series Despatch Ovens are bench ovens to 343°C (650°F) with forced convection airflow.

Model	Volts	Heater watts	Amps	HZ*	Phase
LAD 1-42	240	3,000	15.6	50/60	1
LAD 2-11	208	9,000	29.8	60	3
	240	9,000	26.1	60	3
	480	9,000	13.1	60	3
LAD 2-24	208	16,000	52.4	60	3
	240	16,000	46.0	60	3
	480	16,000	23.0	60	3

* A kit is required for 240V - 1 PH - 50Hz operation. Units will operate on a 220V - 1PH - 50Hz line. Units are modified for 3PH, 50Hz operation

Notice

Users of this equipment must comply with operating procedures and training of operation personnel as required by the Occupational Safety and Health Act (OSHA) of 1970, Section 6 and relevant safety standards, as well as other safety rules and regulations of state and local governments. Refer to the relevant safety standards in OSHA and National Fire Protection Association (NFPA), section 86 of 1990.

Caution

Setup and maintenance of the equipment should be performed by qualified personnel who are experienced in handling all facets of this type of system. Improper setup and operation of this equipment could cause an explosion that may result in equipment damage, personal injury or possible death.

Dear Customer,

Thank you for choosing Despatch Industries. We appreciate the opportunity to work with you and to meet your heat processing needs. We believe that you have selected the finest equipment available in the heat processing industry.

At Despatch, our service does not end after the purchase and delivery of our equipment. For this reason we have created the Service Products Division within Despatch. The Service Products Division features our Response Center for customer service. The Response Center will direct and track your service call to ensure satisfaction.

Whenever you need service or replacement parts, contact the Response Center at 1-800-473-7373: FAX 612-781-5353.

Thank you for choosing Despatch.

Sincerely,

Despatch Industries

PREFACE

This manual is your guide to the Despatch oven. It is organized to give you the information you need quickly and easily.

The INTRODUCTION section provides an overview of the Despatch oven.

The THEORY OF OPERATION section details the function and operation of assemblies and subassemblies on the Despatch oven.

The INSTRUCTIONS section provides directions on unpacking, installing, operating and maintaining the Despatch oven.

The APPENDIX section contains Special Instructions for operating the control instrument, a Troubleshooting Table, a list of Accessories and a Warranty.

An efficient way to learn about the oven would be to read the manual while working with the corresponding oven control system. This will give you practical hands-on experience with information in the manual and the oven.

Before operating the equipment, be sure you understand all of the technical information contained in this manual. Information skipped, not understood or misunderstood could create the possibility of operating the equipment in an unsafe manner. This can cause damage to the oven or personnel or reduce the efficiency of the equipment.

NOTE:
Read the entire
INTRODUCTION and
THEORY OF OPERATION
before installing the oven.

WARNING:
Failure to heed warnings in this
instruction manual and on the
oven could result in personal
injury, property damage or death.

Table of Contents

PREFACE	i
Table of Contents	ii
List of Illustrations	iv
List of Tables	iv
INTRODUCTION	1
Special Features	1
Specifications	2
Dimensions Capacities	3
Power	3
Temperature	4
THEORY OF OPERATION	5
Protocol™	6
Keypad Controls	7
Status Indicator LEDs	8
Operating Modes	8
Manual Mode	8
Timer Mode	9
Program Mode	9
Calibration Zero Offset	10
Tune Setting	11
Protocol™ Hi-Limit	12
INSTRUCTIONS	13
Unpacking and Inspection	13
Set-up	14
Operating	15
Loading the Oven	15
Pre-Startup Checklist	16
Startup	17
Manual Mode	18
Startup	18
Run	18
Stop	19
Timer Mode	20
Startup	20
Manual Stop	22
Program Mode	23
Startup	23
Manual Stop	27
Maintenance	28
Checklist	28
Tests	29
Replacement	29
Parts	29

Table of Contents (Cont.)

Protocol™ Instrument	30
Heater Unit	31
Fan Motor	32
APPENDIX	35
Special Instructions	35
Control Instrument	35
Tune Mode	35
Tuning Outline	36
Tuning Worksheet	37
Calibration Mode	38
Calibration Instructions	38
Diagnostics Mode	44
Power Failure	45
Programming Examples and Outline	46
Example 1 - Manual Mode	46
Example 2 - Timer Mode	47
Program Mode	48
Program Worksheet	50
Example 3 - Program Mode	51
Example 4 - Program Mode	52
Example 5 - Program Mode	53
Troubleshooting	54
Accessories	56
Warranty	57
Despatch Classic™ Service Warranty Program	57
Immediate Service Response	57
Field Service Network	57
Best Service Protection in the Industry!	58
Classic™ Series Warranty	59
Parts and Material	59
Labor and Expenses	59
Exclusions/Limitations of Liability	59
Emergency Service	60
Non-Compliance	60
Despatch Customer Service	61
Procedures and Customer Responsibilities	61
Attachment A - Sustained Service Support	62

List of Illustrations

Figure 1 illustrates the precision horizontal airflow.	5
Figure 2 illustrates the control panel.	6
Figure 3 illustrates the CZO function in the tune mode of Protocol™	10
Figure 4 illustrates the control panel on the LAC Series oven.	17
Figure 5 shows the top view of the J type thermocouple inputs on Protocol™	30
Figure 6 shows the top view of the J type thermocouple inputs on Protocol™	38
Figure 7 illustrates a sample profile.	50
Figure 8 illustrates an example temperature profile.	51
Figure 9 illustrates an example temperature profile.	52
Figure 10 illustrates an example temperature profile.	53
Figure 11 illustrates the Classic™ 4 Plus 1 Service Program . .	58

List of Tables

Table 1 Dimensions	2
Table 2 Capacities	3
Table 3 Power Requirements	3
Table 4 Temperature	4
Table 5 Protocol™ Keypad Controls	7
Table 6 Protocol™ Touchkeys	7
Table 7 Protocol™ Indicator LEDs	8
Table 8 Calibration Zero Offset Examples	11
Table 9 Factory PID Settings	11
Table 10 Tuning Outline	36
Table 11 Tune Mode Parameter Calibration	40
Table 12 Diagnostics Mode Outline	44
Table 13 Manual Mode Example	46
Table 14 Timer Mode Example	47
Table 15 Program Mode Outline	48
Table 16 Accessories	56

INTRODUCTION

This section provides an overview of the Despatch LAD Series ovens. The LAD Series Ovens have the most effective heat distribution and the fastest processing time of any lab oven its size. Air is discharged from the left side wall of the oven and circulates through the chamber.

Special Features

The sturdy construction and 4 inch insulation, (5 inches in the front) of the Despatch LAD Series ovens contribute to excellent temperature uniformity.

Despatch LAD Series ovens also incorporate a modular microprocessor based digital control. The Despatch Protocol™ temperature controller features:

- PID tuning,
- programmable up to 48 segments,
- built-in manual reset Hi-Limit control,
- built-in process timer,
- self-diagnostics,
- digital display,
- three (3) event outputs,
- recursive profile capability,
- optional RS-422/RS-485 capability.

Special Features (Cont.)

Other special features include the following.

- Unique Despatch design to combine higher fan volume of forced recirculated air with a system of perforated stainless steel walls for the ultimate in temperature uniformity.
- Welded double wall construction and fiberglass insulation to reduce heat loss. Silicone rubber gaskets further minimize heat leakage.
- Rapid response heater with a 5 year warranty.
- Scratch-resistant Silver-Clay® baked enamel exterior and stainless steel interior for easy cleaning.
- Space-saving, stackable design on the LAD 1-42 model only.

Specifications

Table 1 Dimensions

Model	Chamber Size in (cm)			Capacity feet ³ (liters)	Overall Size in (cm)			Maximum Number of Shelf Positions
	W	D	H		W	D	H	
LAD 1-42	20 (50)	18 (46)	20 (51)	4.2 (120)	33 (84)	34 (86)	45 (114)	9
LAD 2-11	38 (96)	20 (50)	26 (66)	11.0 (310)	54 (137)	34 (86)	69 (175)	6
LAD 2-24	48 (122)	24 (61)	36 (91)	24.0 (680)	66 (168)	38 (97)	81 (206)	9

Dimensions Capacities

Table 2 Capacities

Model		LAD 1-42	LAD 2-11	LAD 2-24
Maximum Load	Lbs	150	180	300
Maximum Shelf Load	Lbs	30	60	100
Exhaust	CFM	Adjustable to 12	Adjustable to 19	Adjustable to 80
Recirculating Fan	CFM	300	1,000	1,500
	H.P.	¼	1	2
Approximate Weight Net	Lbs.	350	745	1,015
	KG	159	339	461
Approximate Shipping Weight	Lbs.	480	1,045	1,415
	KG	218	475	643

Power

Line voltages may vary in some geographical locations. If your line voltage is much lower than the oven voltage rating, warm up time will be longer and motors may overload or run hot. If your line voltage is higher than name plate rating, the motor may run hot and draw excessive amps.

If the line voltage varies more than 10% from the oven voltage rating, some electrical components such as relays, temperature controls, etc. may operate erratically.

Table 3 Power Requirements

Model	Volts	Amps	Hertz*	Phase	Heater KW
LAD 1-42	240	15.6	50/60	1	3
LAD 2-11	208	29.8	60	3	9
	240	26.1	60	3	9
	480	13.1	60	3	9
LAD 2-24	208	52.4	60	3	16
	240	46.0	60	3	16
	480	23.0	60	3	16

* A kit is required for 240V - 1PH - 50Hz operation. Units will operate on a 220V - 1 PH - 50 Hz line. Units are modified for 3 PH, 50Hz operation.

Temperature

Table 4 Temperature

Model		LAD 1-42	LAD 2-11	LAD 2-24
Time to Temperature (approximate minutes with no load)	25°C - 100°C	6	5	3
	25°C - 200°C	21	14	12
	25°C - 343°C	56	32	30
Recovery Time Door Open 1 Min. (approximate minutes with no load)	100°C	<1	<1	<1
	200°C	3	2	2
	343°C	10	7	4
Temperature Uniformity at	100°C*	±1°C	±1°C	±1°C
	200°C*	±2°C	±2°C	±2°C
	343°C*	±3°C	±3°C	±3°C
Minimum Operating Temperature (Approximate w/20°C ambient)	dampers open	40°C	30°C	30°C
	dampers closed	50°C	40°C	55°C
Control Stability		±0.3°C	±0.3°C	±0.3°C
Repeatability		±0.5°C	±0.5°C	±0.5°C
Cooldown Time (approximate minutes with no load)	343 - 50°C dampers open	108	56	26
	343 - 75°C dampers closed	130	150	200

* Figures are based on actual tests in an empty oven.
Uniformity can vary slightly depending on unit and
operating conditions.

THEORY OF OPERATION

This section details the function and operation of assemblies and subassemblies on the Despatch LAD Series Ovens. These ovens have the most effective heat distribution system and the fastest processing time of any lab oven its size. They are especially useful for testing, preheating, sterilizing, drying, aging and curing as well as other production applications. Horizontal airflow with precision digital control delivers uniform, fast processing. The overall result is efficient productivity under strenuous conditions.




Figure 1 illustrates the precision horizontal airflow.

The unique Despatch computerized design, moves forced convected heat through perforated stainless steel walls. The air is recirculated with a high volume fan. Despatch LAD Series Ovens employ higher volume fans than any competitive model. The chamber can be densely loaded without interfering with the process. Air delivery temperature is within 1°C of the number appearing on the digital display. Also, fresh air intake is regulated by a panel-mounted damper control, while the exhaust rate is fixed. The exhaust rate is regulated by an adjustable control on the exhaust stack (LAD 2-11 and LAD 2-24). The exhaust rate is fixed in the LAD 1-42. The exhaust port, on the back of the LAD 1-42, is covered by a hat bracket. Do not remove the hat bracket.

Protocol™

The ovens are equipped with a modular microprocessor based digital temperature controller.




Figure 2 illustrates the control panel.

The Despatch Protocol™ temperature controller is a dual functioning controller/high limit instrument. The control portion of Protocol™ incorporates a microprocessor to digitally control process variables with minimal temperature fluctuations.

The high limit portion of Protocol™ protects the product and/or the oven itself. If the product being processed has a critical high temperature limit, the Hi-Limit parameter should be set to a temperature somewhat below the temperature at which the product could be damaged. If the product does not have a critical high temperature limit, the Hi-Limit parameter should be set to a value slightly higher than the highest programmed setpoint to protect the oven equipment.

Keypad Controls

The Despatch Protocol™ temperature controller has six keys that provide the six operating modes.

Table 5 Protocol™ Keypad Controls

Mode	Display Code	Function	Description
Manual	MANUAL	Operation	Single setpoint control
Timer	TIMER	Operation	Single setpoint control with process timer
Program	PROGRAM	Operation	Programmable control with three event outputs
Tune	TUNE	Configure	Set instrument parameters
Calibrate	CALMODE	Service	Performs instrument calibration
Diagnostics	DIAGNOSE	Service	Performs instrument thermocouple tests, SSR power level and event output tests.

The Despatch Protocol™ temperature controller also has ten (10) touch-keys so that the user can easily operate the controller.

Table 6 Protocol™ Touchkeys

Key	Description
▲	To move up through any mode
▼	To move down through any mode
+	To increase a setpoint or parameter
-	To decrease a setpoint or parameter
Home	To move to the beginning of any mode or segment
Reset	To reset the control when an error has been corrected or to view the profile number, segment number and the number of loops (repeat times) remaining.
Heater On	To initiate heater relay
Heater Off	To disengage heater relay
Start	To start an operating mode
Stop	To stop an operating mode

Status Indicator LEDs

Protocol™ has seven indicator LEDs that provide the following relevant information to the user.

Table 7 Protocol™ Indicator LEDs

LED	Function
Power on	Lights when the power on pushbutton is pressed.
Heater relay	Lights when a mode is ready for operation and the heater on key is pressed.
Soak Deviation	Lights when the process temperature is not held within the user specified soak deviation limits. The light turns off when the temperature is within the soak deviation limit.
Over Temp	Lights when the process temperature exceeds the high limit value. The over temperature light remains lit until the Reset key is pressed.
Control T/C Error	Lights when Protocol™ receives a control thermocouple error.
Heater on	Lights when the heater is activated by the control circuits.
Hi-Limit T/C Error	Lights when Protocol™ receives a Hi-Limit thermocouple error.

The Despatch Protocol™ temperature controller has been designed for ease of use while maintaining elaborate and versatile control capabilities.

Operating Modes

Protocol™ has three primary modes of operation: the Manual mode, the Timer mode and the Program mode.

Manual Mode

The manual mode is a single setpoint control mode that controls the process at the user specified setpoint for an indefinite period of time. The manual mode controls the oven temperature within close limits as specified by the PID tuning parameters.

Whenever the instrument is powered by the **Power on** pushbutton, Protocol™ starts at the manual mode.

Timer Mode

The timer mode is a single setpoint control mode with a built-in process timer that starts timing either at the beginning of the process or at a user specified temperature. As in the manual mode, the timer mode uses the PID parameters set in the tune mode.

Program Mode

The program mode is a programmable ramp and soak control consisting of up to eight profiles. Each profile consists of up to six segments for a total of 48 segments ($8 \times 6 = 48$). Any one profile may be run recursively from two to 99 cycles or even continuously if it is desired.

Each segment consists of a ramp and soak period. During the ramp period, the control will track oven temperature. For example, a ramp is entered to heat from 100°C to 150°C in 50 minutes. Protocol™ will track the temperature 1°C every minute for 50 minutes. During the soak period, temperature is maintained as specified by the tuning and soak deviation parameters.

Protocol™ will not allow a soak time to begin until the actual oven temperature is within the soak deviation limit. This process is called assured soak. The ramp and soak periods are adjustable from 0 to 99 hours, 59 minutes. Within each ramp and soak period, up to three event outputs can be programmed either on or off.

The event relay is used for factory installed modifications, then disconnected before shipping. Please consult the factory for information on connecting the event outputs. When the events are connected, the user has the capability of controlling relays, solenoid valves, etc., throughout the programming cycle.

Calibration Zero Offset

The Calibration Zero Offset (CZO) of Protocol™ has been preset and tested for the specified operating conditions. Special instructions for accessing the tune mode to change the CZO are referred to in the Appendix of this manual.

NOTE:
The CZO value has been factory preset to match the center of the chamber at 300°C.

CZO 0.0

Figure 3 illustrates the CZO function in the tune mode of Protocol™.

The CZO may be useful to make the following small temperature corrections to the control system.

- Correction of known sensor calibration errors.
- Correction of any known steady temperature offset between the heated work-piece (load) and sensor. This is useful for applications where the sensor cannot be located exactly at the work-piece.
- Alignment of temperature indications in a multi-zone/multi-controller application, e.g., at ambient temperature.

Note that the CZO changes the value of the controlled temperature when used in closed loop control. The CZO function can be represented by the equations:

$$\text{Temp Indication (°F)} = \text{Sensor Temp (°F)} - \text{CZO\%} [100 \text{ (°F)} - \text{Sensor Temp (°F)}]$$

$$\text{Temp Indication (°C)} = \text{Sensor Temp (°C)} - \text{CZO\%} [38 \text{ (°C)} - \text{Sensor Temp (°C)}]$$

The CZO function is a straight line pivoted around 100°F (38°C). Thus, the CZO functions as an offset and has the ability to change the slope of a temperature range.

Calibration Zero Offset (Cont.)

Table 8 Calibration Zero Offset Examples

CZO Display	Temperature measured by sensor	Offset °F	Temperature Indication
0.0	10.0	20.0	100°F
100°F	200°F	0°	0°
20°	100°F	100°F	180°F

NOTE:
The CZO function is easily set for specific operating conditions.

A more useful formula is one that the user can use to calibrate Protocol™ to match the center of the chamber. This requires the use of a temperature measuring device with its thermocouple junction located at the center of the chamber. CZO can be directly calculated by:

$$CZO = 100 \left(\frac{\text{Center Temp } (^\circ\text{F}) - \text{Protocol}^{\text{TM}} \text{ Display } (^\circ\text{F})}{\text{Center Temp } (^\circ\text{F}) - 100 (^\circ\text{F})} \right)$$

$$CZO = 100 \left(\frac{\text{Center Temp } (^\circ\text{C}) - \text{Protocol}^{\text{TM}} \text{ Display } (^\circ\text{C})}{\text{Center Temp } (^\circ\text{C}) - 38 (^\circ\text{C})} \right)$$

Tune Setting

The Protocol™ has been preset and tested for normal operating conditions. Special instructions for changing the tune setting are referenced in the Appendix of this manual.

The Protocol™ on the oven can be manually tuned. For your convenience the factory has tested and preset the PID action to its optimum values. These values need not be changed under normal operating conditions.

Table 9 Factory PID Settings

Proportional Band	Reset Time	Rate Time
5°C	30 seconds/repeat	0 degrees/second

NOTE:
Reset times greater than 35 seconds/repeat are not recommended.

Protocol™ Hi-Limit

Protocol™ will not let the high limit value drop below the setpoint value. In certain situations, it may be necessary to change the setpoint first and then adjust the high limit value.

It will be necessary to reset the Hi-Limit whenever it has tripped. The Hi-Limit may be reset by first allowing the oven chamber to cool slightly (or increasing the parameter by several degrees) and pushing the **Reset** key. During a high limit condition the **Over Temp** LED will turn on thus deactivating the heater.

INSTRUCTIONS

This section provides directions on unpacking, installing, operating and maintaining the Despatch LAD Series Ovens.

Unpacking and Inspection

Remove all packing materials and thoroughly inspect the oven for damage of any kind that could have occurred during shipment.

- See whether the carton and plastic cover sheet inside carton are still in good condition.
- Look at all outside surfaces and corners of the oven for scratches and dents.
- Check the oven controls and indicators for normal movement, bent shafts, cracks, chips or missing parts such as knobs and lenses.
- Check the door and latch for smooth operation.

If there is damage, and it could have happened during shipment follow these instructions.

1. Contact the shipper immediately and file a written damage claim.
2. Contact Despatch Industries to report your findings and to order replacement parts for those that were damaged or missing.
3. Please send a copy of your filed damage claims to Despatch.

Unpacking and Inspection (Cont.)

4. Next, check to make sure you have received all the required materials. Your shipment should include:
 - One (1) Despatch oven,
 - One (1) Instruction manual,
 - One (1) Warranty card,
 - Two (2) Shelves
5. If any of these items are missing from the packaged contents, contact Despatch Industries to have the appropriate materials forwarded to you.
6. Finally, to protect the warranty on your new oven, complete the warranty card and mail it to Despatch within 15 days after receipt of the equipment.

Set-up

1. Place oven on a bench top or an optional cabinet base.

The oven must have a minimum 2 inch clearance in the rear to provide proper ventilation. When placed next to another cabinet, or next to another oven, a 3 inch clearance is required. The doors will still open.

2. Make sure oven is level and plumb; this will assure proper heat distribution and operation of all mechanical components.
3. Identify correct power source indicated on the specification plate.
4. Plug or hardwire oven directly to the electric supply.

WARNING:
All grounding and safety equipment must be in compliance with applicable codes, ordinances and accepted safe practices.

Operating

Users and operators of this oven must comply with operating procedures and training of operating personnel as required by the Occupational Safety and Health Act (OSHA) of 1970, Section 5 and relevant safety standards, and other safety rules and regulations of state and local governments. Refer to the relevant safety standards in OSHA and National Fire Protection Association (NFPA), Section 86 of 1990.

WARNING:

Do not use oven in wet, corrosive or explosive atmospheres unless this oven is specifically designed for a special atmosphere.

Loading the Oven

Despatch Industries cannot be responsible for either the process or process temperature used, or for the quality of the product being processed. It is the responsibility of the purchaser and operator to see that the product undergoing processing in a Despatch oven is adequately protected from damage.

Carefully following the instructions in this manual will help the purchaser and operator in fulfilling that responsibility.

When loading the oven avoid spills of anything onto the heater elements or onto the floor of the oven. Do not place the load on the oven floor plate. This may cause the load to heat unevenly and the weight may cause shorting out of the heater elements. Use the shelves provided.

The two shelves are designed to be pulled out about half way without tipping. The support capacity of the shelves is listed in the Capacities Table in the Specifications section in this manual. Do not overload the shelves.

Distribute the workload evenly so that airflow is not restricted. Do not overfill your oven. The workload should not take up more than two-thirds of any dimension of the inside cavity.

Pre-Startup Checklist

- ✓ Know the system. Read this manual carefully. Make use of its instructions and explanations. The know how of safe, continuous, satisfactory, trouble-free operation depends primarily on the degree of your understanding of the system and of your willingness to keep all parts in proper operating condition.
- ✓ Check line voltage. Voltage must correspond to nameplate requirements of motors and controls. Refer to the section on power connections in the INTRODUCTION of this manual.
- ✓ Fresh air and exhaust. Do not be careless about restrictions in and around the fresh air and exhaust openings and stacks. Under no condition permit them to become so filled with dirt that they appreciably reduce the air quantity. The proper ventilation clearances should be fulfilled at all times. Refer to the Set-up instructions in this manual.
- ✓ Ventilation There is an exhaust opening in the rear of the unit that is covered by a hat bracket. Do not remove the hat bracket as it protects the exhaust opening from being completely covered.
- ✓ Helpful hints

For drying ovens, open vent to prevent buildup of moisture.

For sample heating, close the vent when no ventilation is required.

NOTE:

On the LAD 1-42 the exhaust rate is fixed. The exhaust part is covered by a hat bracket on the back of the unit.

Startup

For fastest oven heat-up time, close the fresh-air vent. After the desired temperature is reached, the vent may be adjusted as needed. An outline and examples for the Manual mode, Timer mode and Program mode are referenced in the Appendix. A completed typical program worksheet accompanies all programmable event outputs installed at the factory.

WARNING:
Do not use flammable solvent or flammable material in this oven.
Do not process closed containers of any substance or liquid in this oven because they may explode under heat.

1. Start the fan.
 - a. Open the oven door.
 - b. Press the **Power on** pushbutton. You will hear the recirculating fan start.
 - c. Shut the oven door.
 - d. Check that the green **Power on** LED is on.




Figure 4 illustrates the control panel on the LAC Series oven.

2. Program the Protocol™ for the desired operating mode. Refer to the following instructions for the Manual mode, the Timer mode and the Program mode.

Manual Mode

Startup

The following are startup instructions for the Manual mode.

1. Select the Manual mode. Press the **Power on** key or the **Manual** key. MANUAL will be displayed.
2. Enter the high limit temperature.
 - a. Press the ▼ key. HI-LIMIT will be displayed.
 - b. Press the ▼ key.
 - c. Use the + or - keys to enter the high limit temperature to a value slightly higher than the intended setpoint.
3. Enter the setpoint.
 - a. Press the ▼ key. SETPOINT will be displayed.
 - b. Press the ▼ key.
 - c. Use the + or - keys to enter the setpoint to the desired operating temperature.

NOTE:

For safety reasons, Protocol™ will not let the operator set the Hi-Limit below the setpoint. It may be necessary to adjust the Protocol™ setpoint first, then adjust the Hi-Limit.

NOTE:

During processing the display shows setpoint on the left and actual oven temperature on the right.

Run

The following are run instructions for the Manual mode.

1. Press the ▼ key. READY will be displayed.
2. Press the **Heater on** key. The **Heater Relay** LED will illuminate.
3. Press the **Start** key. The **Heater on** LED will illuminate and the setpoint and actual temperature will be displayed. As oven temperature approaches setpoint, the **Heater on** LED will cycle on and off.

NOTE:

When Protocol™ is run in the Manual mode, the setpoint can be adjusted without stopping the operation. The setpoint is adjusted by using the + or - keys.

Stop

The following are stop instructions for the Manual mode.

1. Press the **Heater off** key. The **Heater Relay** LED will shut off.
2. Wait for oven temperature to fall below 100°C (212°F).
3. When the Manual mode is complete, press the **Reset** key to display the final process temperatures.
4. Press the **Stop** key.
5. Press the **Power on** pushbutton to turn power off.

An example of the Manual mode is referenced in the Appendix.

Timer Mode

Startup

The following are startup instructions for the Timer mode.

1. Select the Timer mode. Press the **Timer** key. TIMER will be displayed.
2. Enter the high limit temperature.
 - a. Press the ▼ key. HI-LIMIT will be displayed.
 - b. Press the ▼ key.
 - c. Use the + or - keys to enter the high limit temperature to a value slightly higher than the intended setpoint.
3. Enter the setpoint.
 - a. Press the ▼ key. SETPOINT will be displayed.
 - b. Press the ▼ key.
 - c. Use the + or - keys to enter the setpoint to the desired operating temperature.
4. Enter the process time.
 - a. Press the ▼ key. TIME will be displayed.
 - b. Use the + or - keys to enter the time of the process. (HHMM (hours/minutes) or MMSS (minutes/seconds) selected in the tune mode.)

NOTE:

For safety reasons, Protocol™ will not let the operator set the Hi-Limit below the Protocol™ setpoint. It may be necessary to adjust the Protocol™ setpoint first, and then the Hi-Limit.

Startup (Cont.)

5. Enter timer starting temperature.
 - a. Press the ▼ key. TEMP YES/NO will be displayed.
 - b. Use the + or - keys to select either YES or NO.
 - Press the - key to display NO and begin timing at ambient.
 - Press the + key to display YES and begin timing at the following input temperature.
 - c. Press the ▼ key. TEMP and the begin timing temperature will be displayed.
 - d. If YES was selected in step b, use the + or - keys to enter the temperature at which the process timer begins timing.

If NO was selected in step b, this setpoint has no bearing on oven operation.

Run

The following are run instructions for the Timer mode.

1. Press the ▼ key. READY will be displayed.
2. Press the **Heater on** key. The **Heater Relay** LED will illuminate.
3. Press the **Start** key. The **Heater on** LED will illuminate and the setpoint and the actual temperature will be displayed. As the oven temperature approaches the setpoint, the **Heater on** LED will cycle on and off.

NOTE:

During processing the display shows the setpoint on the left and the actual oven temperature on the right.

NOTE:

When the Timer mode is running, pressing the **Start** key will display the time remaining in the cycle. The display will show TRHHMMSS which stands for the time remaining, hours, minutes and seconds.

Manual Stop

The following are manual stop instructions for the Timer mode.

1. Press the **Heater off** key.
2. Wait for oven temperature to fall below 100°C (212°F).
3. When the Timer mode is complete, press the **Reset** key to display the final process temperatures.
4. Press the **Stop** key.
5. Press the **Power on** pushbutton to turn power off.

An example of the Timer mode is referenced in the Appendix of this manual.

Program Mode

Startup

The following are startup instructions for the Program mode. In any one segment, if the ramp and soak times are zero, Protocol™ ignores the remaining segments of the profile. A soak period will not begin until the actual oven temperature is within the soak deviation limit. During any segment of a profile, if the actual oven temperature falls outside of the soak deviation limit, the **Soak Deviation** LED will be illuminated.

1. Select the Program mode. Press the **Program** key. PROGRAM will be displayed.
2. Enter the high limit temperature.
 - a. Press the ▼ key. HI-LIMIT will be displayed.
 - b. Press the ▼ key. The high limit temperature will be displayed.
 - c. Use the + or - keys to enter the high limit temperature to a value higher than the intended setpoints.
3. Enter the profile number.
 - a. Press the ▼ key. PROFILES will be displayed.
 - b. Press the ▼ key. PRO - 1 will be displayed.
 - c. Use the + or - keys to enter the profile number to program.

NOTE:

All profiles entered can be cleared by using the PROF CLR function in the TUNE mode.

NOTE:

For safety reasons, Protocol™ will not let the operator set the Hi-Limit below the setpoint. It may be necessary to adjust the Protocol™ setpoint first, then adjust the Hi-Limit.

Startup (Cont.)

4. Program the profile.
 - a. Press the ▼ key. SEG - 1 will be displayed.
 - b. Program the ramp rate.
 - i. Press the ▼ key. RAMP0001 will be displayed.
 - ii. Use the + or - keys to enter the ramp time.
 - c. Program the events desired during the ramp time.
 - i. Press the ▼ key. EVENTS will be displayed.
 - ii. Press the ▼ key for each event.
 - iii. Use the + or - keys to program the event outputs ON or OFF for the ramp period.
 - d. Program the ramp ending temperature.
 - i. Press the ▼ key. TEMP and the ramp ending temperature will be displayed.
 - ii. Use the + or - keys to enter the desired ramp ending temperature.
 - e. Program the soak time.
 - i. Press the ▼ key. SOAK and the soak time will be displayed.
 - ii. Use the + or - keys to enter the soak time.
 - f. Program the events desired during the soak time.
 - i. Press the ▼ key. EVENTS will be displayed.
 - ii. Press the ▼ for each event.
 - iii. Use the + or - keys to program the event ON or OFF for the soak period.

NOTE:

During processing, the display shows the setpoint on the left and the actual oven temperature on the right.

NOTE:

If all event relays are disconnected or no modifications involving event relays have been made to your particular oven, programming the events has no effect on oven operation.

WARNING:

Never operate the oven at a temperature in excess of the maximum operating temperature.

Startup (Cont.)

- g. Enter the remaining segments 2-6 by following steps a through f.
5. Enter the Soak-Deviation.
 - a. Press the ▼ key until SOAK-DEV is displayed.
 - b. Press the ▼ key. The symbol ± will be displayed.
 - c. Use the + or - keys to enter the soak deviation limit.
 6. Enter the next profile.
 - a. Press the ▼ key. GOTO will be displayed.
 - b. Use the + or - keys to enter the profile number to continue to.

Options include END and 1 through 8. Select **End** to stop at the end of this profile. For continuous profiles enter the same number of the profile that is currently being programmed.
 7. Enter the number of profile recursions.
 - a. Press the ▼ key. REPEAT will be displayed.
 - b. Press the ▼ key. TIMES will be displayed.
 - c. Use the + or - keys to enter the number of times to complete the profile being programmed (1 - 99).

NOTE:

The SOAK-DEV limit is also the assured soak limit. This means that the soak times will not begin until the process temperature is within the SOAK-DEV parameter.

NOTE:

If the Protocol™ is in a hold condition, pressing the **Reset** key will display that the control is in segment 7 (HOLD).

Startup (Cont.)

8. Enter the profile end condition. The hold command is contingent on the final segment of the last profile to be run only.
 - a. Press the ▼ key. HOLD will be displayed.
 - b. Use the + or - keys to select YES or NO.

Selecting YES will hold at last setpoint. The event outputs will be held at their last value.

Selecting NO will not hold at last setpoint. The event outputs will be turned off.

Run

The following are run instructions for the Program mode.

1. Press the **Home** key until PROGRAM is displayed.
2. Press the ▼ key until PRO - 1 is displayed.
3. Make sure the correct starting profile is entered by pressing + or -.
4. Press the ▲ key until READY is displayed.
5. Press the **Heater on** key. The **Heater Relay** LED will illuminate.
6. Press the **Start** key. The **Heater on** LED will illuminate. As the oven temperature approaches the setpoint, the **Heater on** LED will cycle on and off. During processing, the display shows the setpoint on the left and the actual oven temperature on the right.

NOTE:

The SOAK-DEV limit is also the assured soak limit. This means that the soak times will not begin until the process temperature is within the SOAK-DEV parameter.

NOTE:

When in the Program mode, pressing the **Start** key will display the time remaining in the cycle (TRHHMMSS). Pressing the **Reset** key will display the profile number, segment number and the loops (REPEAT TIMES) remaining.

Manual Stop

The following are manual stop instructions for the Program mode.

1. Press **Heater off** key.
2. Wait for oven temperature to fall below 100°C (212°F).
3. Press the **Reset** key to display the final process temperature.
4. Press **Stop** key.
5. Press **Power on** pushbutton to turn power off.

Examples of the Program mode are referenced in the Appendix of this manual.

Maintenance

Do not attempt any service on this oven before opening the main power disconnect switch.

Checklist

- ✓ Keep equipment clean. Gradual dirt accumulation retards air flow. A dirty oven can result in unsatisfactory operation such as unbalanced temperature in the work chamber, reduced heating capacity, reduced production, overheated components, etc. Keep the walls, floor and ceiling of the oven work chamber free of dirt and dust. Floating dust or accumulated dirt may produce unsatisfactory work results. Keep all equipment accessible. Do not permit other materials to be stored or piled against it.
- ✓ Protect controls against excessive heat. This is particularly true of controls, motors or other equipment containing electronic components. Temperatures greater than 51.5°C (125°F) should be avoided.
- ✓ Establish maintenance & checkup schedules. Do this promptly and follow the schedules faithfully. Careful operation and maintenance will be more than paid for in continuous, safe and economical operation.
- ✓ Maintain equipment in good repair. Make repairs immediately. Delays may be costly in added expense for labor and materials and in prolonged shut down.
- ✓ Practice safety. Make it a prime policy to know what you are doing before you do it. Make CAUTION, PATIENCE, and GOOD JUDGEMENT the safety watchwords for the operation of your oven.
- ✓ Lubrication, Fan motor bearings are permanently lubricated. All door latches, hinges, door operating mechanisms, bearing or wear surfaces should be lubricated to ensure easy operation.

Tests

Tests should be performed carefully and regularly. The safety of personnel as well as the condition of equipment may depend upon the proper operation of any one of the functions of the Protocol™. Test the Protocol™ every 40 hours. Check that the heater LED is cycling on and off, indicating that the heater is working. In the manual mode, enter the HI-LIMIT to the same value as the setpoint. Run manual mode.

When the oven temperature reaches setpoint, the Hi-limit should shut down the system. The HI-LIMIT must be manually reset by pushing the **Reset** key.

Replacement

Parts

To order or return parts, contact the Service Products Division at Despatch. The Service Products features our Response Center for customer service. When returning parts, a Despatch representative will provide you with an MRA (Material Return Authorization) number. The MRA number must be attached to the returned part for identification. When you are ordering parts, be sure to give the model number, serial number and the part number. This will expedite the process of obtaining a replacement part.

When you have a service need, contact the **Response Center** at 1-800-473-7373; FAX 612-781-5353.

WARNING:
Disconnect the main power switch or power cord before attempting any repair or adjustment.

Protocol™ Instrument

(Tools needed: one quarter (1/4) inch socket set)

1. Disconnect the power.
2. Remove the screws from the face of the control panel and slide it forward.
3. Disconnect the thermocouple wires and the ground wire.
4. Disconnect any event output wires, noting the proper connections.
5. Disconnect the control panel from the oven by unplugging the quick disconnect plug.




Figure 5 shows the top view of the J type thermocouple inputs on Protocol™.

6. Connect the new control panel to the quick disconnect plug.
7. Connect the thermocouple wires and ground wire.
8. Connect the event output wires (if applicable).
9. Replace the control panel.

Heater Unit

(Tools needed: Crescent wrench, screwdriver, one quarter (1/4) inch socket set)

1. Remove the floor plate.
 - a. Remove the screws from the floor plate.
 - b. Lift the floor plate out of the oven.
2. Disconnect the heater leads from heater element with a wrench. Note which wires go on which terminals.
3. Unscrew the screws holding the heater frame to the oven body.
4. Remove the heater and discard.
5. Screw down the new heater frame.
6. Attach the heater leads to appropriate terminals.
7. Replace the interior floor and screws.

Fan Motor

(Tools needed: Screwdriver, 5/32 inch Allen wrench, one quarter (1/4) inch socket set)

1. Remove the floor plate.
 - a. Remove the screws from the floor plate.
 - b. Lift the floor plate out of the oven.
2. Remove the left side wall.
3. Remove the fan inlet plate.
4. Loosen the set screws (2) on fan wheel in middle of oven bottom. You can reach the fan wheel by going through the heater or by disconnecting and removing the heater. Refer to the Heater Unit instructions.
5. Place the oven on its back.
6. Remove the bottom plate. This will reveal the fan motor.
7. Remove the fan motor.
 - a. Unscrew the screws (4) holding motor mounts to the body.
 - b. Disconnect the motor leads from the terminal strip on the power panel.
 - c. Lift the fan motor from the oven body.

After the fan wheel has run at temperature for awhile, it will stick to the shaft. Some force may be required to separate the fan wheel from the fan motor shaft.

8. Take the motor mounts off old motor.
9. Put the motor mounts onto new motor.

Fan Motor (Cont.)

10. Replace the fan motor.
 - a. Insert the shaft into shaft collar. Put the fan wheel onto shaft from inside oven.
 - b. Reattach the motor mounts to the oven body, making sure grommets are in place.
 - c. Reattach the motor lead wires to the terminal strip.
11. Replace the oven bottom.
12. Turn the oven right side up.
13. Adjust the fan wheel for 3/16 inch clearance between the wheel and the inlet ring.
14. Tighten the set screws on the fan wheel.
15. Check that the set screws hit the flats machined into the motor shaft.
16. Replace the floor plate.

APPENDIX

Special Instructions

The Protocol™ has been preset and tested at the factory for normal operating conditions. In most applications, it will not be necessary to alter oven settings. This section contains additional information and reference for special operating conditions.

Control Instrument

Tune Mode

Various functions of the control instrument are set by parameters in the tune mode. To access the tune mode, it is necessary to enter the proper code.

1. Press **Tune** key. The display reads TUNE.
2. Press **▼** key. CODE *** will be displayed.
3. Enter + - - + - +. PID TUNE will be displayed.

The PID tuning parameters may be entered. The units are listed below.

P = degrees
I = seconds/repeat
D = degrees/second

Tuning Outline

Table 10 Tuning Outline

Display	Description
TUNE	Selects tune mode.
CODE ***	Enter + - - + - +
PID TUNE	Enter tuning parameters.
P-1	Proportional band in degrees (+ or - keys).
I-1	Reset in seconds/repeat (+ or - keys).
D-1	Rate in degrees/second (+ or - keys).
DEG -	Select °C or °F (+ or - keys).
SPL -	Setpoint limit, set to maximum temperature of oven (+ or - keys).
CZO -	Calibration zero offset -99.9 to 99.9 (+ or - keys).
DIS	Time set in MMSS (minutes/seconds) or HHMM (hours/minutes).
BEEP	Select beep on or off (+ or - keys).
PF-RECVR	Power failure recovery mode. Use + or - keys to select from STOP, RESUME or HOLD. STOP Program terminates. Must restart from the beginning of the program. RESUME When power is restored, program resumes at the point where power failure occurred. HOLD Program waits for the operator. The operator has a choice of terminating or resuming the program.
DIG COMM	Digital communications option. Disregard unless Protocol™ is supplied with optional digital communications interface. For proper setting, refer to the Protocol™ software manual or the Digital Communication User Guide. Select from NO COMM, CPIF or ASCII (+ or - keys). Select from RS232C or RS422A (+ or - keys). Select address (ADDR) from 1 to 999 (+ or - keys).
RECONFIG	For saving changes to DIG COMM options in memory.
PROF CLR	Entering code clears all profiles to default values.
VARS CLR	Entering code clears the SRAM in Protocol™. All parameters must be reset. Should be done in EXTREME circumstances only. Recalibration is essential.
CODE *E*	For factory installed modifications. Do not change the code setting.

Experience and experimentation with tuning parameters will guide the user in determining the proper settings when normal conditions are not present.

Tuning Worksheet

In most applications it is not necessary to alter tuning parameters. To enter the tune mode, press **Tune**. TUNE will be displayed. Press \blacktriangledown and enter + - - + - +. Using the \blacktriangledown key and the + or - keys, enter the desired settings. Press the **Home** key when finished.

Display	Setting	Factory Setting	Units
P-1	_____	5	degrees
I-1	_____	30	seconds/repeat
D-1	_____	0	degrees/second
DEG -	_____	C	°F (°C)
SPL -	_____	343	°F (°C)
CZD -	_____	varies	% degrees - calibrated to center chamber at 300°C
DIS -	_____	HHMM	minutes/seconds (hours/minutes)
BEEP	_____	On	off (on)

Notes:

1. The alternate is listed in ().
2. See Table 10, Tuning Outline, for further information regarding display codes.
3. Tuning parameters may change from those set at the factory. Load mass, fresh air and exhaust damper settings will affect tuning parameters. Some experimentation is required to determine optimum settings.

Reset times greater than 35 seconds/repeat are not recommended.

Calibration Mode

Protocol™ has been tested and calibrated at the factory. Under normal operating conditions recalibration should not be necessary. However, if the instrument does not comply with known standards recalibration may be necessary.

Calibration Instructions

We recommend using a certified analog thermocouple simulator/calibration source with less than $\pm 1^\circ\text{F}$ noise. We have experienced signal stability problems with some micro-processor based thermocouple simulator/calibrators which induce an error during the calibration procedure. This error generally results in a non-linear shift in the controller's indicated temperature.

1. Disconnect AC power to the oven.
2. Remove Protocol™ controller to expose thermocouple input terminals.
3. Disconnect control and Hi-Limit thermocouples from controller thermocouple input terminals (Control T/C, and Hi-Limit T/C).




Figure 6 shows the top view of the J type thermocouple inputs on Protocol™.

4. Mark thermocouple leads if not labeled.
5. Connect a 6 foot piece of type J thermocouple lead wire to each of the Control T/C and Hi-Limit T/C terminals.

WARNING:
Calibration equipment without internal ambient compensation provisions requires subtracting the ambient mV signal from the calibration temperature mV signal to calibrate Protocol™ properly.

Calibration Instructions (Cont.)

6. Twist together or jumper the lead wire end not connected to the Control T/C and Hi-Limit T/C terminals. This creates a junction and prevents a control sensor error [S-T/C ERR] and Hi-Limit sensor error [H-T/C ERR] caused by an open thermocouple.
7. Loosely fasten the Protocol™ controller to the oven.
8. Re-connect AC power to the oven.
9. Press the **Power on** pushbutton to energize oven.
10. Press the **Tune** key. The display reads [TUNE].
11. Use the ▼ and ▲ keys to scroll through the tune mode configuration. The controller must be configured to operate in °F (Fahrenheit) and CZ0 should be set to zero (0.0).
 - a. Record initial tune mode parameters prior to making any changes.
 - b. Press the ▼ key. The display reads [CODE ***].
 - c. Press the following key sequence: +, -, -, +, -, +. The display reads [PID TUNE]. Protocol™ is in the tune mode.

All errors must be cleared to perform calibration. Any active error will inhibit the calibration function. To clear a Hi-Limit control error [HL ERROR] caused by lost of calibration (Hi-Limit indication of 500°C or 932°F in the diagnostic mode):

1. Increase the Hi-Limit setpoint to 500°C or 932°F
2. Press the **Reset** key.

NOTE:

or ##.# represents a numeric value or parameter.

Calibration Instructions (Cont.)

- d. Use the following table to change the tune mode parameters.

Table 11 Tune Mode Parameter Calibration

Press	Display	Factory Default Setting	Actual Setting	Press	Adjustable Range
▼ key	P-1 ###	5		+ or - keys	0°C to 500°C 32°F to 932°F
▼ key	I-1 ###	30		+ or - keys	0 to 999 seconds/repeat
▼ key	D-1 ###	0		+ or - keys	0 to 999 degrees/second
▼ key	DEG - C	C		+ key for C or - key for F	
▼ key	SPL ###	maximum designed operating temperature ¹		+ or - keys	0°C to 500°C 32°F to 932°F
▼ key	CZO###.#	can vary		+ or - keys to change parameter to 0.0	-99.9 to 99.9 degrees
▼ key	DIS HHMM	HHMM		+ key for HHMM (hours and minutes) or the - key for MMSS (minutes and seconds).	
▼ key	BEEP ON	ON		+ key for ON or the - key for OFF	

¹ 204°C/400°F, 260°C/500°F, 343°C/650°F

- e. Press the **Manual** key. The display reads [MANUAL].
- f. Allow the controller a thirty (30) minute warm up time before proceeding to the step #13 - CAL MODE.
12. Press the **Cal** key. The display reads [CAL--MODE].
13. Press the ▼ key. The display reads [CODE ***].

Calibration Instructions (Cont.)

14. Press the following key sequence: +, -, -, +, -, +.
The display reads [HCAL ###].
15. To calibrate the control, press the ▾ key. The display reads [SCAL ###].
 - a. Connect the piece of type J thermocouple lead wire to the Control T/C terminals, to a thermocouple simulator.
 - b. Set the simulator to output a type J thermocouple signal.
 - c. Twist together or jumper the piece of type J thermocouple lead wire, wired to the Hi-Limit T/C terminals. This creates a junction and prevents a Hi-Limit sensor error [H-T/C ERR] caused by an open thermocouple. Press the **Reset** key to clear a Hi-Limit sensor error [H-T/C ERR] caused by an open thermocouple.
 - d. Adjust the simulator to supply a 250°F signal.
 - e. Press and hold the - key for approximately three (3) seconds until display indicates 250. If display indicates 932, continue to step f. However, you should verify that the display indicates 250 on step h.
 - f. Adjust the simulator to supply a 450°F signal.
 - g. Press and hold the + key for approximately three (3) seconds until display indicates 450.
 - h. Repeat steps d through g.

Calibration Instructions (Cont.)

16. To calibrate the Hi-Limit control, press the ▲ key. The display reads [HCAL ###].
 - a. Connect the piece of type J thermocouple lead wire, wired to the Hi-Limit T/C terminals, to a thermocouple simulator.
 - b. The simulator should be set to output a type J thermocouple signal.
 - c. Twist together or jumper the piece of type J thermocouple lead wire to the Control T/C terminals. This creates a junction and prevents a control sensor error [S-T/C ERR] caused by an open thermocouple. Press the **Reset** key to clear a control sensor error [S-T/C ERR] caused by an open thermocouple.
 - d. Adjust the simulator to supply a 250°F signal.
 - e. Press and hold the - key for approximately three (3) seconds until display indicates 250. If display indicates 932, continue to step f. However, you should verify that the display indicates 250 on step h.
 - f. Adjust the simulator to supply a 450°F signal.
 - g. Press and hold the + key for approximately three (3) seconds until display indicates 450.
 - h. Repeat steps d through g.
 - i. Press the **Manual** key. The display reads [MANUAL].
17. Press the **Power on** pushbutton to de-energize oven.
18. Disconnect AC power to the oven.
19. Remove Protocol™ controller to expose thermocouple inputs terminals.

Calibration Instructions (Cont.)

20. Disconnect the two pieces of type J thermocouple lead wire connected to the Control T/C and Hi-limit T/C terminals.
21. Re-connect control and Hi-Limit thermocouples to the controller thermocouple terminals (Control T/C, and Hi-limit T/C).
22. Re-install the Protocol™ controller onto the oven.
23. Re-connect AC power to the oven.
24. Press the **Power on** pushbutton to energize oven.
25. Press the **Tune** key. The display reads [TUNE].
26. Reset any tune mode parameters that were changed in step 11 to perform calibration (examples: DEG = F and CZ0 = 0.0).
27. When changes have been completed, press the **Manual** key. The display reads [MANUAL].

The calibration procedure is complete.

Diagnostics Mode

The diagnostics mode is provided to give certain relative information about Protocol™. The following gives an outline of the diagnostics mode.

Table 12 Diagnostics Mode Outline

Display	Description
DIAGNOSE	Select Diagnostics mode.
SSR	Protocol™ SSR output level
EVENTS	Events 1-3 follow
E-1	Event 1 output
E-2	Event 2 output
E-3	Event 3 output
SENS-T/C	Control thermocouple display follows
GOOD	Control thermocouple test and input reading
HL - T/C	Hi-Limit thermocouple display follows
GOOD	Hi-Limit thermocouple test and input reading
PWR	% output
SEN	AD conversion code for control thermocouple
HIL	AD conversion code for Hi-Limit thermocouple

Items that can be adjusted by the user include SSR (ON or OFF), Events E-1, E-2 and E-3 (ON or OFF) and PWR. The SSR and PWR items can be used to test the solid state relay for proper operation. The SSR item allows the SSR to output 100% (ON) or 0% (OFF). The PWR item allows for adjustable output from 0% to 100%. To implement, adjust the PWR level with the +/- keys and turn on the heater relay.

Power Failure

In the event that the power supplied to Protocol™ is insufficient at any point during a running mode, the display will read PWR-FAIL. In the tune mode the user can choose the Power Fail Recovery mode from Stop, Resume and Hold. To restart after a power failure in the hold mode, press the **Start** key to resume oven operation. Otherwise, press the **Reset** key to clear the PWR-FAIL display. Do not shut off the power during a running mode. This creates an error condition and PWR-FAIL will be displayed the next time Protocol™ is powered up. Instead, press the **Stop** key and the **Heater Off** key. This will power off Protocol™ without creating an error condition.

Programming Examples and Outline

The following examples show a step by step procedure for programming Protocol™ in the Manual, Timer and Program modes. Example 1 covers the Manual mode and example 2 covers the Timer mode. A detailed outline covers the Program mode with a programming worksheet and examples 3-5 following the outline.

NOTE:
Do not turn the power off until the oven temperature is below 100°C (212°F).

Example 1 - Manual Mode

Control the process at 250°F

NOTE:
°F is selected in the tune mode.

Table 13 Manual Mode Example

Key	DISPLAY	Description
Manual	MANUAL	Select Manual mode
▼	Hi-Limit	Enter the high limit temperature
▼	HL 200	High limit temperature currently set at 200°F
+	HL 275	Increase high limit temperature to 275°F
▼	SETPOINT	Enter the setpoint
▼	180 75	Setpoint at 180°F, actual oven temperature at 75°F
+	250 75	Increase setpoint to 250°F
▼	READY	Protocol™ is ready to run Manual mode
Heater On	READY	Heater relay initiated, heater ready for power
Start	250 75	Setpoint = 250°F, actual oven temperature = 75°F
Stop	READY	Stop Manual mode
Heater Off	READY	Heater relay LED is off, heater secured off

Example 2 - Timer Mode

Control the process at 200°C for three hours and 15 minutes with the timer beginning at 195°C. Protocol™ will stop automatically when run in Timer mode.

NOTE:
°C and HHMM (hours/minutes) is selected in the tune mode.

Table 14 Timer Mode Example

Key	DISPLAY	Description
Timer	TIMER	Select timer mode
▼	Hi-Limit	Enter the high limit temperature
▼	HL 225	Hi-Limit currently set at 225°C
-	HL 215	Decrease high limit to 215°C
▼	SETPOINT	Enter the setpoint
▼	210 25	Setpoint at 210°C, actual oven temperature at 25°C
-	200 25	Decrease setpoint to 200°C
▼	TIME0010	Timer currently set for ten minutes
+	TIME0315	Increase timer to three hours and 15 minutes
▼	TEMP NO	Timer currently set to begin timing at ambient
+	TEMP YES	Timer set to begin timing at the following temperature
▼	TEMP 79	Timer currently set to begin timing at 79°C
+	TEMP 195	Timer set to begin timing at 195°C
▼	READY	Protocol™ is ready to run Timer mode
Heater On	READY	Heater relay LED on, heater ready for power
Start	200 25	Setpoint = 200°C, actual oven temperature = 25°C
Stop	READY	Stop Timer mode
Heater Off	READY	Heater relay LED is off, heater secured off

Program Mode

Table 15 Program Mode Outline

Display	Description
PROGRAM	Select Program mode.
Hi-Limit	Hi-Limit for Program mode
HL	Enter high limit temperature (+ or - keys).
PROFILES PRO-	Enter profile number (1-8).
SEG-	Segment number of profile (1-6)
RAMP	Ramp time entered
EVENTS E-1 E-2 E-3	Event status for ramp time Event 1 status (ON or OFF) Event 2 status (ON or OFF) Event 3 status (ON or OFF)
TEMP	Ramp ending temperature
SOAK	Soak period of ramp ending temperature
EVENTS E-1 E-2 E-3	Event status for soak period Event 1 status (ON or OFF) Event 2 status (ON or OFF) Event 3 status (ON or OFF)
SOAK-DEV	Soak-Deviation limit for profile (Also assured soak limit)
+/-	Enter soak-deviation limit.
GOTO	Enter profile to GOTO End = Move to REPEAT TIMES command 1 = GOTO profile 1 2 = GOTO profile 2 : 8 = GOTO profile 8
REPEAT TIMES	Enter number of recursions (1-99) 1 = Execute profile 1 times 2 = Execute profile 2 times : 99 = Execute profile 99 times
HOLD	Hold at last setpoint?
YES	Hold at last setpoint indefinitely. Holds event outputs at last value.
NO	No hold at last setpoint. Event outputs turn OFF.

Program Mode (Cont.)

Notes on the Program mode.

- The profile number is manually entered using the + or - keys.
- Six segments exist for each profile.
- If the ramp time and soak time for any one segment is zero, Protocol™ ignores the remaining segments.
- The REPEAT TIMES command is the number of times to execute the profile being programmed.
- The HOLD command is contingent on the final segment of the last profile to be run only.
- A soak time will not begin until the actual temperature is within the soak-deviation limit. (Assured soak limit).
- Make sure the proper starting profile number is displayed in the PRO- prompt before executing the profile to be run.

While a program is being executed, pressing the **Reset** key will display the profile number, segment number and the number of loops (REPEAT TIMES) remaining. Pressing the **Start** key will display the appropriate ramp or soak time remaining (TR.)

If Protocol™ is in a HOLD condition, pressing the **Reset** key will display that the control is in segment 7 (HOLD.)

Program Worksheet

The program worksheet serves as a guide to the input parameters for the program mode.





Figure 7 illustrates a sample profile.

Display	Setting(s)					
HL	_____					
PRO-	_____					
SEG-	1	2	3	4	5	6
RAMP	_____	_____	_____	_____	_____	_____
E-1	_____	_____	_____	_____	_____	_____
E-2	_____	_____	_____	_____	_____	_____
E-3	_____	_____	_____	_____	_____	_____
TEMP	_____	_____	_____	_____	_____	_____
SOAK	_____	_____	_____	_____	_____	_____
E-1	_____	_____	_____	_____	_____	_____
E-2	_____	_____	_____	_____	_____	_____
E-3	_____	_____	_____	_____	_____	_____
SOAK-DEV	_____					
GOTO	_____					
REPEAT TIMES	_____					
HOLD	_____					

Example 3 - Program Mode



NOTES:
 HHMM (hours/minutes) and °C selected in the tune mode. No event outputs are being used. Soak-Deviation limit = $\pm 7^{\circ}\text{C}$ (also assured soak limit). Hold at last setpoint. Ramp and soak times of zero in any one segment ignores remaining segments.


Figure 8 illustrates an example temperature profile.

Follow the characteristic curve listed below.

Display	Setting(s)					
HL	<u>150</u>					
PRO-	<u>1</u>					
SEG-	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>5</u>	<u>6</u>
RAMP	<u>0020</u>	<u>0010</u>	<u>0010</u>	<u>0000</u>	_____	_____
E-1	_____	_____	_____	_____	_____	_____
E-2	_____	_____	_____	_____	_____	_____
E-3	_____	_____	_____	_____	_____	_____
TEMP	<u>100</u>	<u>130</u>	<u>120</u>	<u>120</u>	_____	_____
SOAK	<u>0010</u>	<u>0010</u>	<u>0001</u>	<u>0000</u>	_____	_____
E-1	_____	_____	_____	_____	_____	_____
E-2	_____	_____	_____	_____	_____	_____
E-3	_____	_____	_____	_____	_____	_____
SOAK-DEV	<u>7</u>	_____	_____	_____	_____	_____
GOTO	<u>End</u>					
REPEAT TIMES	<u>1</u>					
HOLD	<u>Yes</u>					

Example 4 - Program Mode

Autostart the oven after two hours and follow the characteristic curve below.



NOTES:

MMSS (minutes/seconds) and °F selected in the tune mode. Event 1 wired properly for autostart, events 2 - 3 are not used. No hold at last setpoint.


Soak-Deviation = $\pm 5^{\circ}\text{F}$ (also assured soak limit). Minimum operating temperature is 70°F .

Figure 9 illustrates an example temperature profile.

Display	Setting(s)					
HL	<u>240</u>					
PRO-	<u>1</u>					
SEG-	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>5</u>	<u>6</u>
RAMP	<u>0001</u>	<u>0100</u>	<u>0030</u>	<u>0100</u>	<u>0100</u>	<u>0030</u>
E-1	<u>OFF</u>	<u>ON</u>	<u>ON</u>	<u>ON</u>	<u>ON</u>	<u>ON</u>
E-2	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>
E-3	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>
TEMP	<u>70</u>	<u>130</u>	<u>160</u>	<u>130</u>	<u>220</u>	<u>100</u>
SOAK	<u>0200</u>	<u>0030</u>	<u>0100</u>	<u>0100</u>	<u>0200</u>	<u>0000</u>
E-1	<u>OFF</u>	<u>ON</u>	<u>ON</u>	<u>ON</u>	<u>ON</u>	<u>OFF</u>
E-2	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>
E-3	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>
SOAK-DEV	<u>5</u>					
GOTO	<u>End</u>					
REPEAT TIMES	<u>1</u>					
HOLD	<u>NO</u>					

Example 5 - Program Mode

Complete characteristic curve five times.



NOTES:
 HHMM (hours/minutes) and °C selected in the tune mode. No events used. Soak-Deviation = 10°C (also assured soak limit). Minimum operating temperature = 50°C. Ramp and soak times of zero in any one segment ignores remaining segments.

Figure 10 illustrates an example temperature profile.

Display	Setting(s)					
HL	<u>115</u>					
PRO-	<u>1</u>					
SEG-	1	2	3	4	5	6
RAMP	<u>0100</u>	<u>0200</u>	<u>0000</u>	_____	_____	_____
E-1	_____	_____	_____	_____	_____	_____
E-2	_____	_____	_____	_____	_____	_____
E-3	_____	_____	_____	_____	_____	_____
TEMP	<u>100</u>	<u>50</u>	<u>50</u>	_____	_____	_____
SOAK	<u>0100</u>	<u>0001</u>	<u>0000</u>	_____	_____	_____
E-1	_____	_____	_____	_____	_____	_____
E-2	_____	_____	_____	_____	_____	_____
E-3	_____	_____	_____	_____	_____	_____
SOAK-DEV	<u>10</u>					
GOTO	<u>End</u>					
REPEAT TIMES	<u>5</u>					
HOLD	<u>NO</u>					

Troubleshooting

Equipment which operates for long periods of time may develop problems. Below are possible problems and suggested solutions. If you have a problem not listed and do not know what to do, contact Despatch Industries at our toll free Help Line 800-473-7373.

<u>Difficulty</u>	<u>Probable Cause</u>	<u>Suggested Remedy</u>
Failure to heat	No power	Check power source and/or oven and wall fuses.
	Broken or frayed cord	Replace with new cord.
	Burned out heater	Replace heater (see warranty.)
	Protocol™ malfunction	Replace controller.
	Loose wire connections	Disconnect power and check connections behind control panel.
Slow heat up	Improperly loaded	Reduce load or redistribute load in chamber.
	Low line voltage	Supply sufficient power and proper connections. Check for circuit overload.
	Heating element(s) are burned out	Replace burned out element (see warranty statement, back page.)
	240 volt oven is connected to a 208V line	Raise line voltage to a 240 volt line.
	Fan motor failure	Replace fan motor.
Frequent heater element out	Harmful fumes generated by load	Increase vent opening or discontinue process.
	Spillage or splattering of material on heater elements	Disconnect power and clean oven chamber and elements.
	Overheating oven	Check the Hi-Limit.

Troubleshooting (Cont.)

<u>Difficulty</u>	<u>Probable Cause</u>	<u>Suggested Remedy</u>
Erratic temp. Inaccurate temp.	Protocol™ malfunction	Replace Protocol™.
	Improper tuning parameters	Check tuning parameters.
	Protocol™ miscalibration	Recalibrate Protocol™ (see section on Calibration mode.)
	Hi-Limit setting	Hi-Limit should be 10-25°C higher than setpoint.
Excess surface or door temp.	Improper offset	Check calibration zero offset.
	Door seal deterioration	Replace door seal.
Improper airflow	Fan motor failure	Replace fan motor.
	Unbalanced fan wheel	Replace fan wheel.
Excessive vibration	Dirty fan wheel	Clean fan.
	Unbalanced fan wheel	Replace fan wheel.
Oven will not control at setpoint	Hi-Limit set too low	Set the Hi-Limit higher.
	Protocol™ malfunction	Replace control.
	SSR malfunction	Replace SSR and/or check control output voltage.
	Air friction of recirculation fan	Open exhaust air vent. Unit will not control below minimum operating temperature with vent closed.
Heater does not shutdown until temp. reaches the Hi-Limit setting	Protocol™ malfunction	Replace Protocol™.
	SSR malfunction	Replace SSR.

Accessories

The ovens have options that can easily be field installed.

Table 16 Accessories

Option	Functional Description
Recorder kit	The round chart recorder follows the temperature changes and records them for permanent record.
Door switch	Disables heater when the door is opened.
Extra shelves	
Stands	This support frame includes one open shelf.
Base cabinets	These steel, 22 inch high cabinets are painted to match the ovens. The cabinets store supplies and hold workloads. A magnetic latch secures the door. Standard Despatch shelves fit in the cabinets. Shelves for base cabinets must be ordered separately.
Stacking kit	Allows ovens to be stacked to save space. Kit includes angles mounted on top of the lower oven to stabilize the upper oven. (LAD 1-42 only)

The above items can all be field installed. For further information on these items or other available options, please contact your Despatch representative.

Warranty

For years Despatch has delivered an exceptional product backed by a strong sense of responsibility and drive for long term customer satisfaction. These business principles enable us to offer the exclusive and comprehensive "Classic™ Four Plus One Service Warranty Program".

Despatch Classic™ Service Warranty Program

The basis of this outstanding, exclusive service program is a four-year replacement warranty covering defects in workmanship or material on all Despatch manufactured components and assemblies. Add to this a comprehensive 1 year parts warranty on the entire unit and you have one of the strongest warranties in the industry.

Immediate Service Response

The key to the Classic™ Service Program is response. A toll free Help-Line connects you to our Customer Service response center giving you immediate access to specialized assistance. Our customer service Product Service Technicians have over 200 years experience and access to detail design and manufacturing documentation specific to your Despatch unit. This exacting level of service is a benefit only Despatch can provide and means that you can expect speedy, accurate and the most cost effective response.

Field Service Network

A growing network of Service Professionals are available to support your Despatch equipment. From routine calibration and preventive maintenance to emergency breakdown response, our service network is positioned to reach 90 percent of our installed base within four hours. This is service you can depend on.

Best Service Protection in the Industry!




Figure 11 illustrates the Classic™ 4 Plus 1 Service Program

** Receive 5th year parts replacement warranty free with purchase of PM+ or Total Service Agreement within the first two years.

Classic™ Series Warranty

Parts and Material

Despatch warrants all parts and assemblies manufactured by Despatch for the Classic™ Series oven to be free from defects in material and workmanship for a period of four (4) years from the date of shipment or start-up, by Authorized Despatch Service Representative, whichever is later.

Despatch further warrants all parts and assemblies to be free from defects in material and workmanship for a period of one (1) year from date of shipment or start-up, by Authorized Despatch Service Representative, whichever is later.

Despatch will repair or replace, at our option, f.o.b. Despatch's factory, parts covered by this warranty. Despatch is not responsible for parts defects resulting from misuse, abuse, acts of nature or utility performance not to Despatch specification including electrical, environmental and fresh air/exhaust provisions.

Labor and Expenses

Despatch Classic™ Series warranty cover parts replacement or repair. Labor and other expenses related to the removal and replacement of such parts are the owners responsibility as is any necessary reprogramming, calibration and certification.

Exclusions/Limitations of Liability

The foregoing warranty shall be deemed valid and binding upon Seller if and only if Purchaser loads, operates and maintains the equipment supplied hereunder in accordance with the instruction manual provided upon delivery of the equipment. Seller does not guarantee the process of manufacture by Purchaser or the quality of product to be produced by subject equipment. This warranty does not cover expenses to diagnose, repair or replace components or associated failures.

Exclusions/Limitations of Liability (Cont.)

Parts failures caused by improper operation, abuse, misuse, acts of nature, and nonconforming utilities and environments are not covered by this warranty.

Despatch shall not in any event be liable for indirect, special, consequential or liquidated damages or penalties, including loss of revenue, profits or business opportunities resulting from interruption of product production. Despatch shall further be held blameless for any damages or expenses resulting from delays in our attempts to diagnose and repair the equipment, unavailability of spare parts or inaccessibility of the equipment. Specifically excluded from this warranty is responsibility for internal and external corrosion damage to the equipment.

Emergency Service

In an emergency situation, Customer agrees to:

1. Immediately shut off fuel or energy supply (gas and electricity).
2. Call 911 for emergency assistance if needed.
3. Call Despatch Service Help-Line at 800-473-7373.

Non-Compliance

Despatch reserves the right to suspend and withhold service as provided under this Warranty in the event of non-compliance by the Customer to any terms and conditions of this Warranty. Further, Despatch is held harmless for any loss of production, incurred expenses, or other inconveniences due to suspension of service under this non-compliance provision.

THE FOREGOING WARRANTY IS EXCLUSIVE AND IN LIEU OF ALL OTHER EXPRESS AND IMPLIED WARRANTIES WHATSOEVER, AND SPECIFICALLY THERE ARE NO IMPLIED WARRANTIES OF MERCHANTABILITY OR OF FITNESS FOR A PARTICULAR PURPOSE.

SEE ATTACHED DESCRIPTION OF DESPATCH CUSTOMER SERVICE PROCEDURES AND RELATED CUSTOMER RESPONSIBILITIES WHICH ARE INTEGRAL TO THIS WARRANTY.

THE FOREGOING WARRANTY IS NOT TRANSFERABLE IN SITUATIONS WHERE EQUIPMENT OWNERSHIP IS TRANSFERRED TO ANOTHER PARTY.

Despatch Customer Service

Procedures and Customer Responsibilities

To provide the most effective service to our customers under this warranty, all requests for repairs are to be initiated by the Customer by telephone to the Despatch Service Help Line, 800-473-7373. The Standard Period of Maintenance (SPM) is defined as 8 a.m. to 5 p.m. local time, excluding weekends and Despatch Holidays. Calls placed within the SPM will be handled as follows.

Help Line calls connect the customer with the Despatch Response Center. The Response Center will record all pertinent information, including SERIAL and MODEL NUMBER of the unit(s), the urgency and nature of the problem, and the name and phone number of the caller or other contact. This information will be passed to the first available service support technician who will research the units serial file so as to be familiar with customer unit when he calls the customer back. Despatch service technicians will make every effort to call back within four (4) working hours, or less, from receipt of the initial call. Despatch will advise the Customer on suggested steps and/or tests to either resolve the problem or help to confirm the diagnosis of the problem.

Customer Agrees to cooperate in performing such tests and attempting to resolve the problem as quickly as possible. Customer also agrees to replace minor parts such as fuses, latches, etc. as instructed by Despatch Service Technicians. This approach has Despatch and the Customer cooperating to effect the most expedient and cost effective repair and minimize down time. If in Despatch's sole judgement, the equipment cannot be repaired in this manner, an on-site visit by a Despatch authorized service representative may be scheduled to repair the equipment. Customer agrees that, when requested and authorized, such charges will be paid by the Customer within 30 days from receipt of invoice.

Attachment A - Sustained Service Support

At Despatch long term customer satisfaction means more than responding quickly and effectively to our customers' service requirements. It means offering comprehensive customer support well beyond the scope of our initial contractual commitment. Despatch's Service Products Division offers a Total Service Agreement package or a Preventive Maintenance Plus agreement (PM+). These service products are unique in the industry and offer the following benefits to our customer:

- Priority response for minimum production interruption.
- Preventive maintenance for longer product life.
- Discount on parts and services where applicable.
- Single payment for reduced billing expense.
- Elimination of need for a separate purchase order for each service requested.

Because these extra service options are aimed at extending our new equipment productivity, we will also extend the Despatch four year manufactured parts warranty for another 12 months. This bonus warranty is automatically yours when you purchase a service agreement from Despatch within the first 12 months after shipment of the equipment.